



Hiltru Barneveld b.v.  
Compagnieweg 14-16  
NL-3771 NH Barneveld  
+ 31 (0)342-404160

www.hiltru.com  
info@hiltru.com

Created on: 26-06-2026 14:17:59 |  
Technical changes and imperfections  
reserved.

## **Specifications F60 Gas bottle depots BSG**

---

Version 1.1 | 11-07-2023

### **HILTRA® BIGSAVER® MODEL BSG GENERAL**

#### **Design/fire resistance:**

- The composite structure was assessed by the accredited testing institute Efectis®.
- Efectis brandwerendheidsrapport: 94-CVB-R1178/2009-Efectis-R0834(Rev.1)/2010-Efectis-R1117-S.
- Designed as an independent fire compartment for the storage of packaged hazardous materials based on the Building Code and guideline PGS 15: 2016 version 1.0.
- Fire resistance (WBDBO) 60 minutes determined in case of a fire from outside and a fire from inside on all criteria of PGS 15:2016 version 1.0, regulation 3.2.9.

#### **Housing (walls, roof and door):**

- Casing made of galvanized sheet piling.
- Interior made of non-combustible and insulating material finished with galvanized sheet.
- The roof is equipped with an integrated rain gutter on both long sides.